

Barrington Passage Sidewalk

Cam

Areas of concern

5.1.2 Curb Ramps

5.1.2.a – Curb Ramp has a tactile attention indicator before the curb ramp meets the street at **crosswalks only**.

5.1.3 Street crossings (crosswalks)

5.1.3.c. If the intersection includes both a traffic light and sidewalk, does it employ a distinct audible indication for each discrete direction of travel ? **No**

5.1.3.d if the intersection is within a 500 m radius of a facility serving the visually impaired, does it employ a distinct audible indication for each discrete direction of travel ? **No**