

BARRINGTON REGIONAL CURLING CLUB

Cam/Boyd/Blair

SIGNAGE AND WAYFINDING

- Raised lettering on washroom doors. (Larger signage with brail.)
- 3D Exit signs required along with more signage in general.
- First Aid Kit, AED and Safety Plan Signage required.

RAMPS AND RAILINGS

- Railings require rounded edges at a minimum. Future or replacement railings should be round allowing for a firm grip.
- Railings are loose – require tightening.
- Ramps leading to ice surface from boardwalk need to be doubled in length. Currently too steep.

BOARDWALK AROUND ICE SURFACE

- Boardwalk is used for the storage of chairs which prevents someone in a wheelchair to gain access to the EXIT.
- Boardwalk corners need to be widened out allowing for a wheelchair to take the corner.

STAIRS

- Paint Stair Treads for contrast.

DOORS AND DOORWAYS

- New kickpad (activation button) for automatic door openers

PUBLIC WASHROOMS

- Expand accessible stall to allow for installation of a wash sink for privacy.

EMERGENCY SYSTEMS

- Fire pulls require signage or arrow above.
- More emergency lighting required.

OTHER

- Storage of Items in front of fire pulls need to be removed.
- Storage of items on wheelchair ramp leading to ice surface need to be removed.