

BARRINGTON REGIONAL CURLING CLUB

SHORT TERM

- Raised lettering on washroom doors. (Larger signage with brail.) - Done
- 3D Exit signs required along with more signage in general.
- First Aid Kit, AED and Safety Plan Signage required.
- Railings are loose – require tightening.
- Boardwalk is used for the storage of chairs which prevents someone in a wheelchair to gain access to the EXIT. - Done
- Paint Stair Treads for contrast.
- Fire pulls require signage or arrow above.
- Storage of Items in front of fire pulls need to be removed. - Done
- Storage of items on wheelchair ramp leading to ice surface need to be removed. - Done

MEDIUM TERM

- New kickpad (activation button) for automatic door openers
- More emergency lighting required.

LONG TERM

- Railings require rounded edges at a minimum. Future or replacement railings should be round allowing for a firm grip.
- Ramps leading to ice surface from boardwalk need to be doubled in length. Currently too steep.
- Boardwalk corners need to be widened out allowing for a wheelchair to take the corner.
- Expand accessible stall to allow for installation of a wash sink for privacy.